


E-Classic 2300 with 3 Pumps Installed



Pump Parts List		
Qty	p/n	Description
3	118	3/4" Close Nipple
3	171	007 Pump
3	198	3/4" Ball Valve
3	224	3/4" Isolation Flange Kits
3	296	3/4" Swing Check Valve
2	388	1-1/4" x 3/4" Bushing
3	533	3/4" x 2" Nipple
3	556	Power Supply Cord, 32"
1	582	6 Outlet Converter
6	1330	3/4" x 1" MPT to PEX
3	3042	1/2" x 1/8" Bushing
6	5926	1" Stainless Steel Clamp Crimp Ring
3	6054	Temperature Gauge
3	6764	3/4" x 3/4" x 1/2" Offset Tee
1	6593	Grounding Rod Kit

Parts and accessories sold separately.
Pump size may vary.

Return Side View




*For 1-1/4" lines use p/n 5871.
Central Boiler recommends installing swing check valves on the return lines to eliminate reverse flow.



Area of Focus

Ground Rod Kit Install



NOTE

Grounding Rod Kit (p/n 6593) must be installed with every furnace.



For illustration purposes only.