

## NOTE

If heating loops are above manifolds, additional controls (e.g. zone valve or flow check) may be needed to prevent ghost flow (see Radiant Heat with Flow-Check Valve illustration).

For illustration purposes only:

- Water heater styles may vary.
- Size of incoming line may vary (depending on application).
- Location of thermostat may vary.

# Dual System (In Floor Radiant / Forced Air)

